2022 Water Quality Report for City of Beaverton

This report covers the drinking water quality for City of Beaverton for the 2022 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2022. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from 2 groundwater wells, each over 80' in depth. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is moderate.

There are no significant sources of contamination include in our water supply. We are making efforts to protect our sources with a wellhead protection program.

If you would like to know more about the report, please contact the City of Beaverton at (989) 435-3511 or pstanley@beavertonmi.org.

- Contaminants and their presence in water:
 Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).
- water than the general population. Immunocompromised persons such as persons with cancer
 undergoing chemotherapy, persons who have
 undergone organ transplants, people with HIV/AIDS
 or other immune systems disorders, some elderly,
 and infants can be particularly at risk from infections.
 These people should seek advice about drinking
 water from their health care providers. EPA/CDC
 guidelines on appropriate means to lessen the risk of
 infection by Cryptosporidium and other microbial
 contaminants are available from the Safe Drinking
 Water Hotline (800-426-4791).
- Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some

cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2022 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2022. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old. **Terms and abbreviation ns used below:**

- <u>Maximum Contaminant Level Goal (MCLG)</u>: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- <u>Maximum Contaminant Level (MCL)</u>: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- <u>Maximum Residual Disinfectant Level (MRDL)</u>: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is
 no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control
 microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable ND: not detectable at testing limit ppb: parts per billion or micrograms per liter ppm: parts per million or milligrams per liter pCi/l: picocuries per liter (a measure of radioactivity).
- <u>Action Level (AL)</u>: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Inorganic Contami	nants		Leanna ann an Aire	A	<u> </u>		
Barium (ppm)	2	2	0.04	N/A	2017	No	Discharge of drilling wastes; Discharge of metal refineries, Erosion of natural deposits
Fluoride (ppm)	4	4	.11	N/A	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium ¹ (ppm)	N/A	N/A	84	N/A	2022	No	Erosion of natural deposits.
Nitrate (ppm) (Can also be Organic)	10	0	.4	N/A	2022	No	runoff or seepage from fertilized agricultural lands, municipal and industrial waste water, refuse dumps, animal feedlots, septic tanks and private sewage disposal systems, urban drainage and decaying plant debris.
Disinfectants & Dis	sinfection	By-Produc	cts				
TTHM - Total Trihalomethanes (ppb)	80	N/A	.0216	N/A	2022	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	.002	N/A	2022	No	Byproduct of drinking water disinfection
Chlorine ² (ppm)	4	4	.75	.61-1.04	2022	No	Water additive used to control microbes
Inorganic Contaminant Subject to AL	AL	MCLG	Your Water ³	Range of Results	Year Sampled	# of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	13		2020	1	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.13		2020	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

¹ Sodium is not a regulated contaminant.

² The chlorine "Level Detected" was calculated using a running annual average.

^{3 90} percent of the samples collected were at or below the level reported for our water.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Beaverton is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at http://water.epa.gov/drink/info/lead

Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Monitoring and Reporting to the EGLE Requirements: The State and EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2022.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at City Hall, 128 Saginaw St, Beaverton MI.

We invite public participation in decisions that affect drinking water quality. Council meetings are held every third Monday of each month at 6:00 PM. Contact City Hall for the location. For more information about your water, or the contents of this report, contact DPW Supervisor, Pat Stanley, at pstanley@beavertonmi.org or (989) 435-7073. A copy can also be found on the City website, http://beavertonmi.org/water-sewer/. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.